

SCHOOL INSPECTION REPORT

School:	
Location:	
Inspected by:	Date:
Report sent to:	

FINDINGS:  = Satisfactory  = Unsatisfactory  = Suggested improvement **N/A** = Not applicable

Room: 1 - Science		
Finding	Description	Citation
	Recommendation: Lockers and bookshelves over 4 feet high should be secured to prevent tipping. If bookcases are stacked vertically, they should be secured together and secured to the wall. Observation: Tall storage shelving in lab storage room is not secured to the wall. Heavy microscopes stored at and above eye-level. Recommended action: Secure lockers/bookshelves as necessary (to a stable wall and each other) to prevent tipping. Move heavy items to lower shelves to prevent a fall/injury hazard.	OSPI and DOH / ASTM F 2440 / NFHS
	Recommendation: No food items (for human consumption) permitted in laboratories or chemical storerooms (including lab refrigerators). No eating or drinking allowed in lab. Food items to be used for experiments and refrigerators used to store them are labeled "Not for human consumption." Observation: Food items stored with science lab materials (Petri dishes, slides) in fridge. Recommended action: Prohibit eating and drinking in the lab. Do not store food items intended for human consumption in the lab. Label all food items to be used for experiments as "Not for human consumption."	29 CFR 1910.141.g.2/4 / PP 6.C.2.3
	Recommendation: Chemical storeroom shelves are secured to the wall. All shelves have $\frac{3}{4}$" spill-prevention ("earthquake") lips on their front edges (closeable cabinet doors do not replace the need for spill prevention lips). Observation: No spill prevention lips for lab glassware storage. Recommended action: Secure chemical storeroom shelves to the wall and install $\frac{3}{4}$" spill prevention lips on the front edges of all shelves.	CFR 1910.1450 App A / FEMA E-74 6.5 / PP 5E 2.D.2

Room: 2 - CTE		
Finding	Description	Citation
	Requirement: All hazardous substances (e.g., cleaning and disinfecting products) are labeled and stored in such a manner as to prevent unauthorized use and possible contamination of food and drink. Observation: Can of Dust-Off in cabinet storage accessible to students. Dust-Off can be used unauthorized as an inhalant. Corrective action: Secure all chemicals and/or cleaning supplies in an inaccessible area (e.g., locked, out of students' reach), away from food and drink.	WAC 246-366-050.6 / WAC 296-800-11040

Room: 3 - Art		
Finding	Description	Citation
	Requirement: Appropriate direct local exhaust ventilation shall be used whenever pottery kilns, lead soldering, 3D printers, laser printers, laser wood cutters, etc., or volatile chemical products	WAC 246-366-080 / OSPI

SCHOOL INSPECTION REPORT

	(such as paints, glues, paint thinners, spray adhesives and fixatives, other solvents, and corrosive acids used in etching) are used indoors. Observation: Observed can of spray adhesive containing acetone Corrective action: REMINDER: Provide mechanical ventilation to adequately remove airborne contaminants of concern while using product. Recommend storing product in flammables cabinet.	
--	--	--

Room: 4

Finding	Description	Citation
	Recommendation: Room is free of essential oils or other fragranced products. Observation: Scented cleaning products Recommended action: Remove all products containing essential oils, perfumes, and other strong fragrances that may aggravate asthma in students	DOH 333-307 November 2022
	Recommendation: Room is free of outside chemicals, cleaners, or disinfectants. Only products provided by the school/district are used. Observation: Outside scented cleaner in classroom Recommended action: Remove any outside cleaners/disinfectants. Use only cleaning supplies that are provided by the school/district.	DOH 333-243 August 2019

Room: 5 - Science

Finding	Description	Citation
	Recommendation: No food items (for human consumption) permitted in laboratories or chemical storerooms (including lab refrigerators). No eating or drinking allowed in lab. Food items to be used for experiments and refrigerators used to store them are labeled "Not for human consumption." Observation: Food items stored in lab storage area. Recommended action: Prohibit eating and drinking in the lab. Do not store food items intended for human consumption in the lab. Label all food items to be used for experiments as "Not for human consumption."	29 CFR 1910.141.g.2/4 / PP 6.C.2.3
	Recommendation: Schools only store and use chemicals appropriate for their grade level. Reference the DOH School Chemical Database for details. Observation: Sodium lumps in storage. Per WA DOH, sodium lumps are appropriate only for advanced level high school science classes. Recommended action: Ensure that the lab is not storing any high-risk chemicals (see DOH School Chemical Database).	WAC 246-366-140 / OSPI-DOH

Room: 6

Finding	Description	Citation
	Recommendation: Room is free of upholstered furniture, blankets, stuffed animals, and other objects with soft, difficult-to-clean surfaces that can harbor dirt, dust, mites, and other common asthma triggers. Observation: Upholstered items, bean bags Recommended action: Remove or replace any rugs, upholstered furniture, and other soft, difficult-to-clean objects. Remove blankets/stuffed animals or wash them in hot water every two weeks.	IAQBMPM / EPA IAQ TFS

SCHOOL INSPECTION REPORT

345 6th St, Suite 300
Bremerton, WA 98337
360-728-2235

	Recommendation: Room is free of outside chemicals, cleaners, or disinfectants. Only products provided by the school/district are used. Observation: Clorox wipes in classroom Recommended action: Remove any outside cleaners/disinfectants. Use only cleaning supplies that are provided by the school/district.	DOH 333-243 August 2019
Room: 7		
Finding	Description	Citation
	Recommendation: Room is free of upholstered furniture, blankets, stuffed animals, and other objects with soft, difficult-to-clean surfaces that can harbor dirt, dust, mites, and other common asthma triggers. Observation: Upholstered items, blankets, rugs Recommended action: Remove or replace any rugs, upholstered furniture, and other soft, difficult-to-clean objects. Remove blankets/stuffed animals or wash them in hot water every two weeks.	IAQBMPM / EPA IAQ TFS
Room: 8		
Finding	Description	Citation
	Recommendation: See below. Observation: Butane canisters found in cupboard. Recommended action: Highly recommend moving these highly flammable canisters to a designated flammables cabinet.	See description for applicable citation.
Room: 9 - CTE		
Finding	Description	Citation
	Recommendation: Room is free of outside chemicals, cleaners, or disinfectants. Only products provided by the school/district are used. Observation: Febreze sprays, essential oils in classroom Recommended action: Remove any outside cleaners/disinfectants. Use only cleaning supplies that are provided by the school/district.	DOH 333-243 August 2019
	Recommendation: See below. Observation: Recommendation: No spray adhesives or fixatives that contain toluene or hexane are present. Observation: Extremely flammable sprays (x2) contain hexane. Recommended action: Remove supplies containing toxic materials and replace with safer alternatives.	See description for applicable citation.
	Requirement: Flammable liquids in excess of ten gallons total are stored in approved flammable storage cabinets with self closing doors as required by the state fire code. Observation: Extremely flammable sprays (x2) found in regular storage cabinet. Corrective action: Store flammable liquids in an approved flammable storage cabinet.	51-54A/IFC 5704.3.4.4 / WAC 296-24-33009
Room: 10		
Finding	Description	Citation
	Requirement: All hazardous substances (e.g., cleaning and disinfecting products) are labeled and stored in such a manner as to prevent unauthorized use and possible contamination of	WAC 246-366-050.6 / WAC 296-800-11040

SCHOOL INSPECTION REPORT

	food and drink. Observation: Several cans of marking paint spray were located in a cardboard box on the floor of the classroom. Corrective action: Secure all chemicals and/or cleaning supplies in an inaccessible area (e.g., locked, out of students' reach), away from food and drink.	
Room: 11		
Finding	Description	Citation
	Recommendation: Room is free of outside chemicals, cleaners, or disinfectants. Only products provided by the school/district are used. Observation: Lysol spray Recommended action: Remove any outside cleaners/disinfectants. Use only cleaning supplies that are provided by the school/district.	DOH 333-243 August 2019
Room: 12 - Science		
Finding	Description	Citation
	Recommendation: Room is free of outside chemicals, cleaners, or disinfectants. Only products provided by the school/district are used. Observation: Clorox wipes in classroom Recommended action: Remove any outside cleaners/disinfectants. Use only cleaning supplies that are provided by the school/district.	DOH 333-243 August 2019
	Requirement: Flammable liquids in excess of 10 gallons total are stored in approved flammable storage cabinets with self-closing doors. Cabinets are locked or located in a locked room when not in use. Flammables (red labels), acids, and bases shall each be stored separately. Observation: Isopropyl alcohol stored in regular cabinet Corrective action: Store qualifying flammable chemicals in an approved flammable storage cabinet. Do not use the flammable storage cabinet to store other chemical hazard classes.	WAC 296-24-3309 / NFPA 45 8.3.4 / 51-54A IFC 5704.3.4.4, CH57 / WAC 173-303-630 / PP 5.E.5

General remarks and recommendations: Thank you for meeting with Kitsap Public Health District's School Health and Safety Inspector. Overall, the school was found to be substantially compliant with applicable Washington state school health and safety regulations. Observed deviations from health and safety regulations and/or recommendations are noted above. If you have any questions or concerns, please feel free to contact me.